



NOTES:

LENGTH AS REQUIRED TO PUT OPERATING NUT TWO (2) FEET FROM SURFACE. EXTENSIONS ARE REQUIRED WHEN THE VALVE NUT IS MORE THAN FOUR (4) FEET BELOW FINISHED GRADE. EXTENSIONS ARE TO BE A MINIMUM OF TWO (2) FEET LONG. ONE EXTENSION IS TO BE USED PER VALVE.

ALL EXTENSIONS ARE TO BE MADE OF STEEL, SIZED AS NOTED, AND PAINTED WITH TWO (2) COATS OF METAL PAINT.



VALVE OPERATING NUT EXTENSION

REVISION DATE MAY 17, 2011	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 27, 2023
FILE NAME W-14.DWG		DWG. NO.	W-14