



## SINGLE SERVICE

**NOTES:**

1. DO NOT BACKFILL UNTIL ALL BRASS FITTINGS HAVE BEEN INSPECTED BY THE DISTRICT.
2. WATER METER BOXES SHALL BE A MINIMUM OF 5 FEET FROM POWER VAULTS, HANDHOLES, STREET LIGHTS AND ELECTRICAL SERVICES AND SHALL BE A MINIMUM OF 3 FEET FROM OTHER WATER METERS, SERVICES, FIRE HYDRANTS AND BLOWOFF ASSEMBLIES.
3. METER BOX SHALL BE SUPPLIED BY DEVELOPER OR CONTRACTOR AND SHALL BE PER STANDARD DETAIL W-18.
4. FIBER WASHER TO BE USED IN DOUBLE PURPOSE UNIONS.
5. 1" METER SETTER TO BE USED FOR 5/8" X 3/4" METERS WITH ADAPTERS. DISTRICT TO PROVIDE ADAPTERS AT THE TIME OF METER INSTALLATION.
6. INCLUDE 14 GAUGE SOLID CORE COATED TRACER WIRE FROM WATER MAIN TO METER BOX. INCLUDE 2-FT OF ADDITIONAL WIRE IN METER BOX.



## METER SETTER DETAIL

|                                 |              |   |                                 |
|---------------------------------|--------------|---|---------------------------------|
| REVISION DATE<br>APRIL 17, 2023 | SCALE<br>NTS | DISTRICT APPROVAL<br><i>Gregory G. Hill, P.E.</i> | DATE APPROVED<br>APRIL 27, 2023 |
| FILE NAME<br>W-16.DWG           |              |   | DWG. NO.   <b>W-16</b>          |