



NOTES:

SINGLE SERVICE

1. BRING NEW WATER SERVICE INTO METER BOX AND INSTALL METER SETTER, ETC. TO MEET VERTICAL AND HORIZONTAL ALIGNMENT SPECIFICATIONS.
2. DO NOT BACKFILL UNTIL ALL BRASS FITTINGS HAVE BEEN INSPECTED BY THE DISTRICT.
3. WATER METER BOXES SHALL BE A MINIMUM OF 5 FEET FROM POWER VAULTS, HANDHOLES, STREET LIGHTS AND ELECTRICAL SERVICES AND SHALL BE A MINIMUM OF 3 FEET FROM OTHER WATER METERS, SERVICES, FIRE HYDRANTS AND BLOWOFF ASSEMBLIES.
4. METER BOX SHALL BE SUPPLIED BY DEVELOPER OR CONTRACTOR AND SHALL BE PER STANDARD DETAIL W-18.
4. FIBER WASHER TO BE USED IN DOUBLE PURPOSE UNIONS.
5. 1" METER SETTER TO BE USED FOR 5/8" X 3/4" METERS WITH ADAPTERS. DISTRICT TO PROVIDE ADAPTERS AT THE TIME OF METER INSTALLATION.
6. INCLUDE 14 GAUGE SOLID CORE COATED TRACER WIRE FROM WATER MAIN TO METER BOX. INCLUDE 2-FT OF ADDITIONAL WIRE IN METER BOX.



INSTALLATION DETAIL FOR NEW SERVICE TRANSFER TO EXISTING METER

REVISION DATE APRIL 11, 2023	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 27, 2023
FILE NAME W-16A.DWG			DWG. NO. W-16A