



NOTES:

1. MEGA-LUGS SHALL NOT BE USED ON EXISTING WATER MAIN PIPE IF EXISTING PIPE IS CLASS 50 D.I. OR A.C. PIPE. MJ SLEEVE TO BE INSTALLED ON CLASS 50 D.I. PIPE. TRANSITION COUPLING TO BE INSTALLED ON A.C. PIPE. BLOCKING SHALL BE DETERMINED IN FIELD BY DISTRICT FIELD REPRESENTATIVE.
2. SANITARY SEWER SHOULD BE LOCATED BELOW WATER MAINS IF POSSIBLE. GRAVITY SEWERS MAY BE LOCATED ABOVE WATER MAINS AS LONG AS THERE IS 18" MIN. SEPARATION AND THE WATER MAIN IS CASED FOR AT LEAST 10' EACH SIDE OF THE CROSSING.
3. PRESSURE SEWER MAINS SHALL ONLY BE LOCATED BELOW WATER MAINS WITH 18" MIN. SEPARATION. WATER MAIN SHALL ALSO BE CASED FOR 10' EACH SIDE OF CROSSING.



TYPICAL UTILITY / WATER MAIN CROSSING

REVISION DATE MAY 17, 2011	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 27, 2023
FILE NAME W-32.DWG			DWG. NO. W-32