



NOTES:

1. CONNECTION TO EX. PIPE:  
 DI TO DI: MJ X MJ  
 DI TO AC: ROMAC 501  
 DI TO CI: ROMAC 501  
 VERTICAL BLOCKING IS REQUIRED AT ALL VERTICAL BENDS WITH STRAPPING.
2. SANITARY SEWER SHOULD BE LOCATED BELOW WATER MAINS IF POSSIBLE. GRAVITY SEWERS MAY BE LOCATED ABOVE WATER MAINS AS LONG AS THERE IS 18" MIN. SEPARATION AND THE WATER MAIN IS CASED FOR AT LEAST 10' EACH SIDE OF THE CROSSING.
3. PRESSURE SEWER MAINS SHALL ONLY BE LOCATED BELOW WATER MAINS WITH 18" MIN SEPARATION. WATER MAIN SHALL ALSO BE CASED FOR 10' EACH SIDE OF CROSSING.



## VERTICAL REDIRECTION OF SCWSD WATER MAIN

REVISION DATE DECEMBER 20, 2021	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 27, 2023
FILE NAME W-35A.DWG			DWG. NO.   W-35A