



ELEVATION

NOTE:
 MAXIMUM ALLOWANCE FOR INSTALLATION IS A 22 1/2° MANUFACTURED BEND.



STANDARD PLAN STUB SERVICE (ALT. NO. 2)

REVISION DATE MAY 17, 2011	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 18, 2023
FILE NAME S-6.DWG		DWG. NO.	S-6