



NOTE:
 CONSTRUCTION OF SIDE SEWER
 ON THE BUILDING SITE SUBJECT
 TO DISTRICT REQUIREMENTS
 FOR INSTALLATION, TESTING
 AND APPROVAL.

ELEVATION

NOTE:
 MAXIMUM DEFLECTION PER JOINT NOT OVER 2" PER
 FOOT, OR 5" PER STANDARD 30" PIPE SECTION. (NOT
 TO EXCEED PIPE MANUFACTURER'S SPECIFICATIONS)



**STANDARD PLAN STUB SERVICE
 FOR MANUFACTURED HOME**

REVISION DATE MAY 17, 2011	SCALE NTS	DISTRICT APPROVAL Gregory G. Hill, P.E.	DATE APPROVED APRIL 18, 2023
FILE NAME S-8.DWG		DWG. NO.	S-8