



NOTE: SEE PAGE 4 OF 5 FOR CONSTRUCTION REQUIREMENTS.

GENERAL NOTES

- ① 2 - 45° BENDS WITH 24" MIN. SEPARATION BETWEEN BENDS TO EQUAL 90° BEND.
- ② CONNECTION TO MAIN STACK FROM SIDE SEWER SHALL BE DUCTILE IRON OR PVC PIPE WITH A STRONG BACK COUPLING. IF OVER 6-FT DEEP, ROMAC TYPE COUPLING OR APPROVED EQUAL REQUIRED.
- ③ 4" WYE, TEE OR BACKWATER VALVE FOR CLEANOUT AND TESTING.
- ④ 18" MINIMUM OR 30" MAXIMUM DISTANCE FROM HOUSE. IF ACCESS IS PREVENTED BY PORCH OR DECKS, THEN SURFACE CLEAN-OUT IS REQUIRED (SEE DETAIL NO. 30). ALTERNATE DISTANCE MAY BE USED, SUBJECT TO APPROVAL BY DISTRICT.
- ⑤ 18" MINIMUM COVER.
- ⑥ 5'-0" MINIMUM BELOW STREET CENTERLINE OR 3'-6" MINIMUM BELOW EASEMENT LINE ELEVATION, WHICHEVER IS DEEPER @ THE PROPERTY OR EASEMENT LINE.
- ⑦ STANDARD 4" TO 6" INCREASER.
- ⑧ 6'-0" MINIMUM BELOW ROAD GRADE OR CURB LINE.
- ⑨ 6"x6"x6" TEE SHALL BE LOCATED INSIDE PRIVATE PROPERTY.



TYPICAL HOUSE CONNECTION FOR GRAVITY SEWER

REVISION DATE DECEMBER 1, 2022	SCALE NTS	DISTRICT APPROVAL Gregory G. Hill, P.E.	DATE APPROVED APRIL 18, 2023
FILE NAME S-19A.DWG			DWG. NO. S-19A