



NOTE: SEE PAGE 4 OF 5 FOR CONSTRUCTION REQUIREMENTS.

GENERAL NOTES

- ① 6" TEE x MJ CAP TAPPED WITH 1-1/4" NPT. TEE SHALL BE LOCATED ON PRIVATE PROPERTY.
- ② 1-1/4" HDPE ON-SITE SERVICE LINE WITH STAINLESS STEEL TRACER WIRE, 7x7 AIRCRAFT CABLE, 1/8" DIAMETER ALONG TOP OF HDPE FORCE MAIN AND WARNING TAPE MARKED "SEWER" 12" ABOVE.
- ③ GRINDER PUMP.
- ④ GRINDER PUMP. PUMP CONTROL PANEL. LOCATION MUST BE IN DIRECT LINE OF SIGHT FROM GRINDER PUMP, 3' MIN., 5' MAX. ABOVE GROUND. CONTROL WIRE TO BE PLACED IN 1" MIN. CONDUIT FROM PANEL TO GRINDER PUMP.
- ⑤ GRAVITY HOUSE SERVICE TO GRINDER PUMP.
- ⑥ CONTACT THE DISTRICT TO SCHEDULE AN ON-SITE PRECONSTRUCTION MEETING PRIOR TO ANY WORK.



TYPICAL HOUSE CONNECTION FOR ALT. GRAVITY SEWER STUB

REVISION DATE MARCH 15, 2023	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED APRIL 18, 2023
FILE NAME S-19B.DWG		DWG. NO.	S-19B