



ELEVATION

END VIEW

GENERAL NOTES:

1. PROVIDE DISTRICT APPROVED SUPPORT AND OUTSIDE ENCLOSURES FOR ASSEMBLIES LARGER THAN 2" DIAMETER.
2. OWNER SHALL FURNISH, INSTALL, TEST, AND MAINTAIN THE RPBA AND ALL PIPING AND APPURTENANCES SHOWN ON THIS PLAN. THE RPBA SHALL BE ACCESSIBLE TO THE DISTRICT AT ALL TIMES.
3. THE ASSEMBLY MUST BE PROTECTED FROM FREEZING, SEVERE WEATHER, AND ACCIDENTAL DAMAGE.
4. THE RPBA SHALL BE LOCATED IMMEDIATELY BEHIND THE WATER METER.
5. DRAIN SHALL BE SIZED IN ACCORDANCE WITH AWWA CROSS CONNECTION MANUAL 6-8.
6. RPBA MUST BE ON WASHINGTON STATE APPROVED LIST, MUST BE TESTED UPON INSTALLATION BY A WASHINGTON STATE CERTIFIED BACKFLOW ASSEMBLY TESTER, INSTALLED PER MANUFACTURER SPECIFICATIONS TO RETAIN WARRANTIES, AND MUST BE TESTED ANNUALLY THEREAFTER. SUCCESSFUL TEST RESULTS MUST BE REPORTED ANNUALLY TO THE DISTRICT.
7. RPBA MUST BE RETESTED IF MOVED OR REPAIRED.
8. FACILITY IS OWNED AND MAINTAINED BY PROPERTY OWNER FOLLOWING CONSTRUCTION.
9. NO CONNECTIONS SHALL BE MADE BEFORE BACKFLOW PREMISE ISOLATION.



**REDUCED PRESSURE
BACKFLOW ASSEMBLY (RPBA)**

REVISION DATE JUNE 25, 2025	SCALE NTS	DISTRICT APPROVAL <i>Gregory G. Hill, P.E.</i>	DATE APPROVED JUNE 25, 2025
FILE NAME W-37.DWG			DWG. NO. W-37