

Soos Creek Water and Sewer District 2022 Water Quality Report

Where Does Our Water Come From?

Soos Creek Water and Sewer District (SCWSD) is proud to provide you with water that meets or exceeds all federal drinking water quality standards.

The Seattle Public Utilities (SPU) Cedar River Watershed supplies 100% of this high-quality water. This surface water source is located in a remote and uninhabited area of the Cascade Mountains. Rain and snow runoff from the Cascades are held in lakes in the watershed. The Cedar River Watershed is publicly owned



Lake Youngs

and SPU has an aggressive watershed plan to protect it. Agricultural and industrial activities are not allowed within the watershed, and access to the watershed is restricted to appropriate staff and educational programs conducted by SPU staff.

This pristine water is screened, disinfected with chlorine, and fluoridated. A small amount of lime is also added to control corrosion to pipes. Ozonation (a form of oxygen used for disinfection) improves the taste of the water, and ultraviolet light (UV) kills any disease-causing Giardia and Cryptosporidium in the water. The water is then piped and pumped into SCWSD reservoirs and distribution mains which bring the water to area homes and businesses.

Water Quality

In order to ensure that tap water is safe to drink, the Dept. of Health (DOH) and the Environmental Protection Agency (EPA) prescribe regulation that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and the

WA State Dept. of Agriculture regulations establish limit for contaminants in bottled water that must provide the same protection for public health.

Drinking water, including bottled water, may reason ably be expected to contain small amounts of some contaminants. The presence of such contaminants does


not necessarily indicate that the water poses a health risk. More information about contaminants' potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline: (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population would be. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from contaminants. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).



Water Supply Update

As of May 31, 2023, water consumption for the previous seven days averaged approximately 141 million gallons per day (mgd). That is about 30 mgd more than the 111 mgd consumed during the same period last year, and more than the average of 123 mgd used during the same period over the years 2010-2019. Based on current conditions and forecasts, Seattle Public Utilities (SPU) anticipates the regional water system will have sufficient water supply for people and fish this summer. As always, SPU will continue to carefully monitor conditions daily. Using water wisely is something SPU and Soos Creek Water & Sewer District encourage our customers to do. For information about ways to save water, visit www.savingwater.org.



Source Water Assessment

The Dept. of Health (DOH) conducted a source water assessment to determine potential contaminant sources. According to DOH, all surface waters in Washington are given a susceptibility rating of "high," regardless of whether contaminants have been detected or whether there are any sources of contaminants in the watershed. Information on the Source Water Assessment Program is available on the DOH website, at https://doh.wa.gov/community-and-environment/drinking-water/source-water/gis-mapping-tool. Some potential natural sources of contamination include:

- Microbial contaminants, such as viruses, bacteria, and protozoa from wildlife.
- Inorganic contaminants, such as salts and metals, which are naturally occurring.
- Organic contaminants, which result from chlorine combining with the naturally occurring organic matter.

Monitoring

Seattle Public Utilities staff monitors the source water, treatment processes, and distribution system water quality 365 days a year. Different parameters are monitored and analyzed at varying frequencies generally daily, monthly, quarterly, or annually, in accordance with Federal and State regulations. Some elements of the treatment process are monitored continuously. The data, contained in the tables that follow, reflects the 2022 compliance data for Seattle Public Utilities and Soos Creek Water and Sewer District. If sampling was not required in 2022, levels indicated are for the most recent monitoring conducted. Our 2022 routine water quality monitoring did not identify the presence of any contaminants at established levels of concern for the general consumers.

Conservation Benefits Salmon

We share our water with the entire ecosystem. Each gallon you save stays in our rivers and lakes to sustain salmon, wildlife, and forests.



2022 Water Quality Monitoring Results

		EPA's Allowable Limits		Levels in Cedar Water			
Detected Compounds	Units	MCLG	MCL	Average	Range	Typical Sources	
Total Organic Carbon	ppm	NA	П	0.72	0.39 - 0.97	Naturally present	
Turbidity	NTU	NA	П	0.35	0.19 to 1.93	Soil Runoff	
Arsenic	ppb	0	10	0.43	0.34 to 0.52	Erosion of natural deposits	
Barium	ppb	2000	2000	1.26	1.02 to 1.43	Erosion of natural deposits	
Bromate	ppb	0	10	0.4	ND to 5	By-product of drinking disinfection	
Fluoride	ppm	4	4	0.7	0.6 to 0.8	Water additive which promotes strong teeth	
Nitrate	ppm	10	10	0.1	One Sample	Erosion of natural deposits	
Total Trihalomethanes	ppb	NA	80	31	12.9 - 58.5^	By-products of drinking water chlorination	
Haloacetic Acids (5)	ppb	NA	60	30^	13.6 – 50.4^	By-products of drinking water chlorination	
Chlorine	ppm	MRDLG	MRDL	1.02	0.12-1.73*	Water additive used to control microbes	

[^] Results from SCWSD Stage 2 Disinfection Byproducts Routine Monitoring in 2022 * SCWSD Service Area

Definitions

MCLG: Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL: Maximum Residual Disinfectant Level - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfectant Level Goal - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TT: Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

NTU: Nephelometric Turbidity Unit - Turbidity is a measure of how clear the water looks. The turbidity MCL that applied to the Cedar supply in 2022 is 5 NTU.

NA: Not Applicable ppb: 1 part per billion =

ND: Not Detected 1 ug/L = 1 microgram per liter

ppm: 1 part per million =

1 mg/L = 1 milligram per liter

1 ppm =1000 ppb

SCWSD Unregulated Contaminants Monitoring Rule 4 (UCMR4) Sampling Data

UCMR4 data is reported to let you know about new contaminants that may be regulated in the future. The EPA requires us to monitor contaminants that do not have defined health-based standards, and uses this information to determine the occurrence of contaminants in drinking water systems that may lead to future regulations. You can find this information in previous reports on the District website at:

https://www.sooscreek.com/services/water-quality.



Lead and copper monitoring results (Cedar WSA)

Parameter and Units	MCLG	Action Level+	2022 Results*	Homes Exceeding Action Level	Source	
Lead, ppb	0	15	2.2	0 of 50	Corrosion of household	
Copper, ppm	Copper, ppm 1.3		0.05	0 of 55	plumbing system	

- * 90th Percentile: i.e. 90 percent of the samples were less than the values shown.
- + The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Regional Water Conservation Program

Soos Creek Water & Sewer District (SCWSD) adopted the Saving Water Partnership (SWP) Regional Conservation Program Water Use Efficiency Goal: Keep the total average annual retail water use of SWP members under 110 mgd through 2028, despite forecasted population growth, by reducing per capita water use.

SCWSD is one of a group of 19 utilities that purchase wholesale water from Seattle Public Utilities (SPU) and is part of the Saving Water Partnership Regional Water Conservation Program administered by SPU. In 2021, the Saving Water Partnership met the Regional Conservation Program goal, with annual retail water use of members of the Saving Water Partnership at 95.5 mgd.

SCWSD purchased 1.3 billion gallons of water in 2022. Of this, approximately 39 million gallons was lost to distribution system leakage (DSL). Expressed as percentage of water supplied to SCWSD's service area, the DSL loss rate was 3.02%.

The Washington State Department of Health's Water Use Efficiency Rule requires a 10% or less DSL based on a 3-year rolling average. SCWSD is in compliance with this standard.

Highlights of the Regional Water Conservation Program in 2022

In 2022, the Regional Conservation Program continued to offer the virtual program options instituted during COVID-19, and returned to some in-person offerings. We continued to offer customers many ways to conserve.

Rebates were available for:

- Single family residential customers:
 Premium 1.1 gpf (or less) toilets
- Multifamily property owners:
 Premium 1.1 gpf (or less) toilets, and irrigation system upgrades
- Business, industrial, and institutional customers: commercial laundry, food steamers, cooling and

refrigeration systems, medical equipment, irrigation systems, process water improvements, and other water use technologies

The youth education program sponsored 447 presentations for K-8 grade students. 40% were in-classroom, and 60% used

a virtual format.

The commercial program promoted Report Leaks placards, conservation supplies, water use assessments and technical assistance to businesses.

Free Savvy Gardener classes were offered by SWP partners to enable gardeners to create and maintain healthy gardens and landscapes.

Educational messages motivated customers and reminded them to take actions that save water, for example:

- Find and fix toilet and faucet leaks mailing to 95,000 homes
- How Much Water Does Your Toilet Use?
- Water plants wisely
- Mulch garden beds to retain moisture longer
- Plant the "Right Plant in the Right Place" for healthier gardens

For more information, see the 2021 Regional Water Conservation Program Annual Report, available on-line at www.savingwater.org.



